

**From:** John Peiserich [<mailto:John@ppgmrlaw.com>]

**Sent:** Tuesday, July 22, 2014 11:06 AM

**To:** External - Tyson Nelson; Bobby Johnson

**Cc:** John Peiserich; Michael Christian

**Subject:** 420.02 (b)

Gentlemen –

The language should be revised to state “. . . used to line the bottom and sides of the containment reservoir . . .”. Taking out either is not the best solution as it would require the entire dike to be constructed of liner material which wouldn't have the structural integrity that we seek.

John